

Residential OVERHEAD Service Upgrade/Panel Replacement

Service Bus Size	Existing Service Minimum Conductor Allowed	New Construction Standard
100/125	#2	1/0
200	1/0	2/0
225	2/0	2/0
400	4/0	4/0

Residential UNDERGROUND Service Upgrade/Panel Replacement

Service Bus Size	Service Conductor Size Allowed		
	Existing Direct Bury	Existing in Conduit	New Construction in Conduit
100/125	1/0	1/0	1/0
200	1/0	2/0	4/0
225	2/0	4/0	4/0
400	500	500	(2)-4/0

* No underground flexible conduit allowed on panel upgrades